

**Section 002330****LOW PRESSURE SEWER SYSTEMS****PART 1 - GENERAL**

The following specification is intended for use for the design, selection of materials and construction of low pressure sewer system projects. The low pressure sewer systems, if applicable, shall meet the requirements of the Florida Department of Environmental Protection (FDEP) permit.

1.1 SCOPE**1.1.1 General**

This specification provides the requirements for low pressure sewer system construction for the project.

1.1.2 Work Included

The Contractor shall, unless specified otherwise, furnish all labor, materials, equipment, tools and all other associated appurtenances, necessary to do the work required under the contract to include but not limited to unloading, hauling, and distributing all pipe, casting, fittings, valves and appurtenances. The Contractor shall also remove any surfacing as required; excavate the trenches and pits to the required dimensions; construct and maintain all required for traffic control; sheet, brace, and support the adjoining ground or structures where necessary; handle all drainage or ground water; provide barricades, guards, and warning lights; lay and test the pipe, valves, fittings, and appurtenances; backfill and consolidate the trenches and pits; maintain all surfaces over the trench until surface restoration is completed; restore the surfaces unless otherwise stipulated; remove surplus excavated material; and clean the site of the work.

The Contractor shall also furnish all labor, materials, equipment, tools and all other associated appurtenances required to rearrange sewers, conduits, ducts, pipes, or other structures encountered in the installation of the work.

1.1.3 Location of the Work

The location of this work is as shown on the Contract Documents.

1.1.4 Coordination of the Work

The Contractor shall be responsible for the satisfactory coordination of the construction of the low pressure sewer systems with other construction and activities in the area. Delays in work resulting from lack of such harmony shall not in any way be a cause for extra compensation by any of the parties.

1.1.5 Working Hours

The work shall be carried out in accordance with local ordinance and not to cause any unreasonable nuisance to affected residents. Under emergency conditions, this limitation may be waived by the consent of Charlotte County Utilities (CCU).

1.2 **METHOD OF MEASUREMENT & PAYMENT**

The work shall be measured and the compensation determined in the following manner:

1.2.1 Low Pressure Sewer System Main

Direct bury and directional drill low pressure sewer system main shall be paid for at the contract bid price per lineal foot for each size and type of material specified which shall include the cost of furnishing all pipe, pipe bend sections, jointing material, restraints, stainless steel stiffeners, bedding material and all other appurtenances, and of delivering, handling, laying, dewatering, trenching, sheeting and backfilling, furnishing and installing flowable fill used for tunneling/defecting pipe under and adjacent to existing storm piping/structures (unless separate bid item is provided), testing, restoring the surface (unless separate bid item is provided), necessary permits, and all material or work necessary to install the pipe complete in place at the depth specified on the plans and/or as directed by CCU.

The lengths of pipe for direct bury installation for which payment is made shall be the actual overall length measured along the axis of the pipe without regard to tee sections or bend sections. All lengths shall be measured in a horizontal plane unless the grade of the pipe is more than fifteen percent (15%). No payment consideration will be given to depth zones for the installation of the low pressure main.

The length of pipe for directional bore installation shall be measured by measuring the length pipe before installation and subtracting the lengths of the pipe cut from the ends of pipe when the bore pipe is connected to the pipe on either end. The difference is the length of the pipe in the ground.

1.2.2 Ductile Iron Fittings

Ductile iron fittings shall be paid for by the contract bid price by weight (latest revision of AWWA C153) and shall include all labor, equipment, materials and all associated appurtenances to install the ductile iron fittings. Restraints shall be considered incidental to the ductile iron fittings contract bid price and no direct compensation will be made therefore. Any other items necessary for the installation of the ductile iron fittings that are not included in the manufacturer's specified weight, including but not limited to bolts, gaskets, jointing materials, labor, and testing shall be considered incidental to the project.

1.2.3 Low Pressure Cleanout Assembly

The low pressure cleanout assembly shall be paid for at the contract bid price per each which shall include the cost of furnishing low pressure cleanout assembly device, piping, tees, fittings, 2" plug valve and box, 2" PVC ball valve, meter box, restraints and any other appurtenances and of delivering, handling, excavation, sheeting, backfilling, dewatering,

restoring of the surface and all material or work necessary to install the unit complete in place at the depth specified on the plans. Testing shall be included in the piping test.

1.2.4 Locate Balls and Marker Tape

- a. Locate balls shall be paid for at the contract bid price per each which shall include all labor, equipment, materials and associated appurtenances to install and program the marker balls and submit the marker ball data to Charlotte County Utilities (CCU).
- b. Marker tape shall be considered incidental to the low pressure sewer system mains.

1.2.5 Service Connections

Service connections shall be paid for as outlined below and shall include all labor, equipment, materials, and all associated appurtenances to completely install service connections.

- a. Service connection piping shall be paid for as per the contract bid price per lineal foot installed for each size;
- b. Brass Nipple shall be paid for as per contract bid price per each installed for each size.
- c. Service saddle shall be paid for as per contract bid price per each installed for each service size.
- d. Brass Gate Valve shall be paid for as per contract bid price per each installed for each size. The male adaptor shall be considered incidental to the contract bid price for each brass gate valve and no direct compensation will be made therefore
- e. Swing Check Valve shall be paid for as per contract bid price per each installed for each size.
- f. Ball Valve shall be paid for as per contract bid price per each installed for each size.
- g. Low Pressure Tanks shall be paid for as per contract bid price per each installed for each size. The hatches, covers, pump chamber, outlet piping, inlet piping, floats, concrete patio stones and all other associated appurtenances shall be considered incidental to the contract bid price for each low pressure tank and no direct compensation will be made therefore.
- h. Low Pressure Pumps shall be paid for as per contract bid price per each installed for each size. The electrical panels, electrical conduit, electrical wiring and all other associated appurtenances shall be considered incidental to the contract bid price for each low pressure pump and no direct compensation will be made therefore.

1.2.6 Meter Boxes for Low Pressure Cleanout Assembly

- a. Meter boxes and covers for the low pressure cleanout assembly shall be rated as follow:

For low vehicle traffic areas such as side walk, property line/easement shall be at a minimum ANSI/SCTE Tier 8 rated potable water and reclaimed water meter boxes and covers.

The following product(s) are approved for Tier 8:

GlasMasters model numbers:

- S151712F3N08-5 (box low pressure cleanout assembly) (colored green)
- S1517PN08-5-CCWW (lid low pressure cleanout assembly) (colored green)

or CCU approved equal.

For medium vehicle traffic areas such as residential driveways, roadways, and parking lots shall be at a minimum ANSI/SCTE Tier 15 rated meter boxes and covers.

For high vehicle traffic areas such as county arterial roadways, state roads, commercial driveways, industrial parks shall be at a minimum ANSI/SCTE Tier 22 rated meter boxes and covers.

- b. Meter boxes and covers shall be color impregnated or painted based on the meter box and cover materials and be green in color
- c. Meter box covers shall have a hinged access panel to facilitate the reading of the meter. All meter boxes shall be delivered with the service access holes installed.
- d. Meter boxes, required purchase from CCU, shall be installed as a double configuration.

1.2.7 Testing

All required testing shall be considered incidental to the project and no direct compensation will be made therefore.

1.2.8 Miscellaneous

All other items required for the completion of the project and not included as a specific bid item shall be considered incidental to the project and no direct compensation will be made therefore.

1.3 **REFERENCED STANDARDS (LATEST REVISION)**

ANSI/AWWA: C110/A21.10, C-900, C-905, C-909, C906-90, C 151,
C153/A21.53, C111/A 21.11, C-651, and C-652

ASTM: A-139, B-1785, C-857, D-790, D-1120, D-1248, D-1598,
D-1599, D-1693, D-1869, D-2241, D-3350

AASHTO Code

FDEP: Wastewater Collection/Transmission System Requirements

Florida Building Code: Plumbing, Chapter 10

Florida Administrative Code: 64E-6.013 Florida Health Department Guidelines

International Association of Plumbing and Mechanical Officials (IAPMO) PS 1

Plumbing and Drainage Institute G101

Ten States Recommended Standards for Wastewater

1.4 PARTIAL LISTING OF RELATED SECTIONS

001570 - Erosion and Sediment Control

001760 - Surveying and Record Drawings

002240 - Dewatering

002310 - Pipe Removal, Disposal, Alteration, Modification or Pipe Abandonment

002325 - Force Mains

002340 - Valves

002530 - Submersible Sewage Pump Lift Station-Package Design

002540 - Submersible Sewage Pump Lift Station- Standard Design

002930 - Grassing

003300 - Precast Concrete Products

009900 - Surface Preparation Painting and Coating

Note: This is only a partial listing of related sections. The Contractor shall be responsible to review the entire contract documents

1.5 SUBMITTALS

For only those materials that the Contractor is requesting deviations from these specifications, the Contractor shall submit in writing documentation to justify approval of these materials by Charlotte County Utilities (CCU) prior to the start of the project. The Contractor shall submit four (4) signed copies of the material submittals.

The contractor submittals shall include the statement that the submittals have been reviewed and the materials meet the contract specifications and/or standard details.

The Contractor shall provide proof of supplier certification/training for butt fusing pipe for any employee fusing pipe.

Final approval is at the discretion of CCU.

PART 2 - PRODUCTS

2.1 MATERIALS

2.1.1 General

Low Pressure Sewer Systems Mains shall be a minimum of three (3) inches in diameter.

The materials used in this work shall be all new and conform to the requirements for class, kind, size and material as specified below.

All pipe furnished for low pressure sewer systems main installations shall be of the type, kind, size, and class indicated for each particular line segment as shown on the engineering drawings and/or designated in the Contract Items.

2.1.2 Polyvinyl Chloride (PVC) Pressure Pipe and Fittings

- a. PVC pipe for low pressure system mains shall conform to the requirements of AWWA C-900 (4" through 12"), AWWA C-905 (14" through 36"), and AWWA C-909 (4" through 24") and shall be Class 150 DR 18 for all open cut and direct bury installations with a minimum of forty eight (48) inches of cover. For shallower depth, the type of pipe and installation shall require prior CCU approval. Three (3) inch diameter pipe shall be schedule 40 or 80 PVC conforming to the requirements of ASTM B-1785. The manufacturer shall insure all quality control test and AWWA requirements are complied with during the production of PVC pipe.
- b. C-900, C-905, and C-909 pipes shall have an integral bell formed with a race designed to accept the gasket in accordance with their respective AWWA requirements. The spigot end shall have a bevel and a stop mark on the outside diameter to indicate proper insertion depth. Provisions shall be made for expansion and contraction at each joint. All surfaces of the joint where the gasket may bear shall be smooth, free of cracks, fractures, or imperfections that could adversely affect the performance of the joint.
- c. Schedule 40 and 80 PVC piping shall be joined by solvent cements, adhesive, or threaded type connections. These materials shall be specifically approved in writing by CCU prior to their use.
- d. Pipe Color: All C-900, C-905, and C-909 low pressure sewer system main piping shall be green in color with a PVC ASTM D-1120 and ASTM D-2241 reference, the class pressure rating, and the DR number permanently and plainly marked on the pipe. For schedule 40 or 80 PVC piping marker tape stripes shall be installed and shall be green in color.
- e. Rubber Gasket Joints: C-900, C-905, and C-909 polyvinylchloride pipe joints shall be the bell and spigot type using rubber gasket push-on type joints. Gaskets shall be molded to a circular form to the proper cross section and shall consist of a vulcanized high grade elastomeric compound conforming to ASTM D-1869 and AWWA C-900 elastomeric seals for joining plastic pipe.
- f. DIP Fittings: All ductile iron fittings shall be in accordance with AWWA Specification C-153 and as a minimum have the same pressure rating of the connecting pipe. All ductile iron fittings shall be either:
 - fusion bonded epoxy coated as per AWWA Specification C-116
 - or
 - ceramic epoxy coated as per ASTM Specifications F-4176-95A, G-95, B-117, D-1308 and E-96

All exposed fasteners such as bolts, nuts, washers, and threaded rod shall be Type 316 stainless steel and all buried fasteners such as bolts, nuts, fasteners, washers, and threaded

rod shall be “Cor-Ten” steel or Cor-blue coated. Mechanical joint bolts shall not protrude more than ½ inch through the nut after joints are assembled.

- g. PVC Fittings: PVC fittings shall be only be used on schedule 40 or schedule 80 PVC piping in accordance with ASTM B-1785 and have the same pressure rating of the connecting pipe. All PVC fittings shall be solvent welded.
- h. Fastener Threads: All stainless steel fasteners threads shall be coated with an anti-seize compound as approved by CCU.

2.1.3 High Density Polyethylene (HDPE) Pipe and Fittings

- a. High Density Polyethylene (HDPE) pipe shall meet the requirements of AWWA C906 for polyethylene pressure pipe and fittings and for PE-3408 (SDR 11). HDPE pipe shall meet ASTM D-3350 cell classification of PE 345434C. Permanent identification of the pipe shall be provided by co-extruding green longitudinal stripes into the pipes outside surface for low pressure sewer system mains. All polyethylene piping shall have ductile iron pipe nominal outside diameters.

Individual sections of HDPE piping shall be joined together by thermal butt-fusion to make a continuous section of pipe as recommended by the pipe manufacturer. Bends in HDPE pipe shall not be within ten (10) pipe diameters from any fitting or valve. The minimum radius of curvature shall be thirty (30) pipe diameters and bending shall not cause kinking. HDPE piping shall not be joined by solvent cements, adhesive, or threaded type connections.

The color marking stripes shall be aligned during the fusing process, and the pipe shall be pulled through the bore to allow identification of the type of system utilizing the HDPE pipe.

- b. All fittings and sleeves used with high density polyethylene (HDPE) pipe shall be fusion bonded epoxy coated ductile iron with mechanical joints rated to 350 psi and conforming to AWWA C-153 and C-111. All MJ fitting connections to polyethylene pipe shall be restrained with Mega-Lug restrainers. The HDPE pipe shall be reinforced on the fitting ends using stainless steel wedge internal stiffeners

The mechanical connection to MJ fittings and sleeves shall use mechanical restraints that meet specification requirements. Size-on-size mechanical connection to PVC or DI pipe shall be by compact ductile iron solid sleeves with Mega-Lug restrainers.

No electro fusion fittings shall be used with HDPE unless specific written approval is provided by CCU.

HDPE molded butt fittings and couplings shall require special approval from CCU for installation.

2.1.4 Ductile Iron Pipe and Fittings

- a. The ductile iron pipe covered by this specification shall be the push-on joint type or mechanical joint type, centrifugally cast to conform to all requirements of AWWA Specifications C-151 and C-153, latest revisions.

The maximum allowable deflection of the pipe shall not exceed two percent (2%) of the pipe diameter. Ductile iron pipe will be fully encased in an 8 mil polyethylene sleeve, in accordance with AWWA C-150, Method A. The pipe and the polyethylene sleeve shall be color coded green by a means acceptable to CCU.

- b. All piping and fittings shall be either:
 - fusion bonded epoxy coated as per AWWA Specification latest revision
 - or
 - ceramic epoxy coated as per ASTM Specifications F-4176-95A, G-95, B-117, D-1308 and E-96
- c. Polyethylene material shall conform to ASTM Standard Specification D1248-68, latest revision. All ductile iron piping shall be marked "DUCTILE IRON" in large letters. The nominal wall thickness shall be plainly marked on each piece of pipe and the pipe installed so that the markings can be read from the top of the trench.

Minimum thickness of ductile iron pipe shall be as follows:

3" Ductile Iron Pipe	0.25"	Class 51
4" Ductile Iron Pipe	0.26"	Class 51
6" Ductile Iron Pipe	0.25"	Class 50
8" Ductile Iron Pipe	0.27"	Class 50
10" Ductile Iron Pipe	0.29"	Class 50
12" Ductile Iron Pipe	0.31"	Class 50
14" Ductile Iron Pipe	0.33"	Class 50
16" Ductile Iron Pipe	0.34"	Class 50
18" Ductile Iron Pipe	0.35"	Class 50
20" Ductile Iron Pipe	0.36"	Class 50
24" Ductile Iron Pipe	0.38"	Class 50
30" Ductile Iron Pipe	0.39"	Class 50
36" Ductile Iron Pipe	0.43"	Class 50
42" Ductile Iron Pipe	0.47"	Class 50
48" Ductile Iron Pipe	0.51"	Class 50
54" Ductile Iron Pipe	0.57"	Class 50

- d. Rubber gasket joints shall be in accordance with AWWA Specification C-111 latest revision.
- e. All fittings shall be in accordance with AWWA Specification C-153 latest revision and have the same pressure rating of the connecting pipe. All ductile iron fittings shall be fusion bonded epoxy coated. All exposed fasteners such as bolts, nuts, washers, and threaded rod shall be Type 316 stainless steel. All buried fasteners such as bolts, nuts, washers, and threaded rod shall be "Cor-Ten" steel or Cor-blue coated steel. Mechanical joint bolts shall not protrude more than 1/2 inch through the nut after joints are assembled.
- f. All stainless steel fastener threads shall be coated with an anti-seize compound as approved by CCU.

2.1.5 Service Connections

Existing CCU approved products are listed below for each category. Other products shall not be used until a thorough evaluation is completed by CCU to determine if the same standards are met. Final approval by CCU is required in writing to confirm acceptability.

- a. Low pressure sewer system service connections pipe shall be Schedule 40/80 pipe conforming to the requirements of ASTM B-1785 and be permanently marked with the type/size/use of the pipe. For schedule 40 or 80 PVC piping marker tape stripes shall be installed and shall be green in color.
- b. Fittings for Low Pressure Service Connections shall be Schedule 40/80 PVC conforming to the requirements of ASTM B-1785. For schedule 40 or 80 PVC piping marker tape stripes shall be installed and shall be green in color.
- c. Service Saddles:

All service saddles shall conform to AWWA standards and shall meet CCU standard details as determined by CCU.

The following product(s) are approved:

Ford	FC202
A.Y. McDonald	4855A
Cascade	CSC2
Power Seal	3417DI
A.Y. McDonald	4835A
Romac	202NS

Service Saddles for HDPE pipe include fusion bonded HDPE saddles as per AWWA standards.

- d. Brass Nipple.

All brass nipples shall conform to AWWA standards and shall comply with CCU standard details as determined by CCU.

- e. Brass Gate Valve

All Brass Gate Valve shall conform to AWWA standards and shall comply with CCU standard details as determined by CCU.

The following product(s) are approved:

American	3R
Nibco	T113
A.Y. McDonald	FULL PORT

f. Male adaptor

All male adaptors shall conform to AWWA standards and shall comply with CCU standard details as determined by CCU.

The following product(s) are approved:

Nibco/Lasco	SCH 80
Spears	SCH 80
Tigre (old Vassallo)	SCH 80
Charlotte Foundry	SCH 80

g. PVC Fittings

All PVC Fittings shall conform to AWWA standards and shall comply with CCU standard details as determined by CCU.

The following product(s) are approved:

Nibco/Lasco	SCH 40/80
Spears	SCH 40/80
Tigre (old Vassallo)	SCH 40/80
Charlotte Foundry	SCH 40/80

h. Swing Check Valve.

All PVC Fittings shall conform to AWWA standards and shall comply with CCU standard details as determined by CCU.

The following product(s) are approved:

Flow Controls	1520-20
---------------	---------

i. Ball Valve

All PVC ball valve shall conform to AWWA standards and shall comply with CCU standard details as determined by CCU.

The following product(s) are approved:

Hayward	TC100 SERIES
Spears	2239 / 2232 SERIES
Proflo	

2.1.6 Low Pressure Tanks

2.1.6.1 Non-Traffic Load Bearing

All low pressure tanks for non-traffic load bearing applications shall comply with CCU standard details as determined by CCU.

- a. Low Pressure Tanks shall be made of Fiberglass, Concrete, or HDPE
- b. All low pressure tanks shall meet or exceed the following specifications and shall be designed, constructed and structurally tested in accordance with the latest revision of:
 - Chapter 64E-6.013, Florida administrative code (FAC) Florida Health Department Guidelines
 - Florida building code-plumbing, chapter 10
 - ASTM C-857 minimum structural design
 - Plumbing and drainage institute G101
 - International Association of Plumbing and Mechanical Officials (IAPMO) PS 1
 - ASTM D 1248 polyethylene plastics extrusion materials
 - ASTM D 1693 test method for stress-cracking
 - ASTM D 790 flexural properties of unreinforced and reinforced plastics
- c. In addition, concrete tanks must comply with the following requirements:
 - Inside and outside surfaces of concrete tanks shall be lined in accordance with Section# 003300 Precast Concrete Products. The Contractor shall notify CCU of the intended lining location to allow coordination of the inspection of the lining application.
- d. The following product(s) are approved:
 - Fiberglass tank: Alpha H-20
 - Concrete tanks meeting this specification
 - HDPE tank: Roth Global Plastics (Fralo) CCU-RMT-900HPV24P2 or CCU-RMT-1060HPV24P2

2.1.6.2 Traffic Load Bearing

- a. All low pressure tanks for traffic load bearing applications shall be constructed of concrete materials only and shall require shop drawing submittals for CCU review and approval.
- b. Inside and outside surfaces of concrete tanks shall be lined in accordance with Section# 003300 Precast Concrete Products. The Contractor shall notify CCU of the intended lining location to allow coordination of the inspection of the lining application.

2.1.7 Low Pressure Sewer Pump Chamber

All low pressure sewer pump chambers shall comply with CCU standard details will specifically denote which type of pump chamber to use for each type of tank material being installed.

2.1.8 Low Pressure Pumps

All low pressure pumps shall comply with CCU standard details as determined by CCU.

The following product(s) are approved:

High Head	Barnes	EHV512	.5 HP
High Head	Champion	CPE5	.5 HP
High Head	Milwaukee	LE5-1	.5 HP

2.1.9 The Electrical Panels

All the electrical panels shall comply with CCU standard details as determined by CCU.

The following product(s) are approved:

S1-CC: CCU Simplex Control Panel with an enclosure type rated NEMA 4X (UL listed) as manufactured by Orenco, Hydromatic, Best Controls, Alpha General or approved equivalent in accordance with CCU standard details.

Relay shall be Crouzet # 84134011, 25 amp, solid state with heat sink.

2.1.10 The Electrical cables

All the electrical cables shall conform to NEC and ICDA standards with P-MSHA approval and shall comply with CCU standard details as determined by CCU.

2.1.11 Pipe and Fittings Unloading at Site

The Contractor shall inspect each shipment of pipe and fittings and make provisions for a timely replacement of any damaged material. The Contractor shall unload by hand or use canvas slings to avoid scratching the pipe. The Contractor shall not sling or drag pipe over an abrasive surface. Pipe or fittings damaged during handling shall be removed from the site and replaced with new pipe and/or fittings. The Contractor shall follow the manufacturer’s storage specification and store pipe and fittings in such a manner that prevents damage due to crushing, piercing, excessive heat, harmful chemicals, and exposure to sunlight.

2.1.12 Marker Balls and Marker Tape

- a. Low pressure system main marker balls shall be 3M 4 inch marker ball model 1424XR/ID and green in color.
- b. Low pressure system mains and service connections shall be green in color or provided with green marker tape stripes.

PART 3 - EXECUTION

3.1 CONSTRUCTION REQUIREMENTS

Direct Bury, Directional Bore, Jack and Bore, and Moling: All direct bury, directional bore, jack and bore, and moling low pressure sewer system main pipes shall be installed to a minimum depth of forty-eight (48) inches or as approved by CCU. The Contractor shall satisfactorily maintain the specified cover by a means approved by CCU. If additional fittings are required where not shown on the engineering drawings to maintain alignment around curves, the Contractor shall provide the required number and be compensated at the unit price as proposed on the bid form.

NOTE: If the new construction is tying into existing utilities, the Contractor shall verify the existing utilities, such as fittings and valves, are restrained prior to the start of installation of the valve or piping. If not restrained, the Contractor shall notify CCU in writing and shall restrain the existing utility as approved by CCU.

3.1.1 Direct Bury of Material

- a. Open cut PVC LPFM piping shall be Class 150 DR-18 for all areas with a minimum of forty eight (48) inches of cover. For shallower depth, the type of pipe and installation shall require prior CCU approval.
- b. Proper implements, tools, and facilities satisfactory to CCU shall be provided and used by the Contractor for the safe and convenient execution of the work and the testing. All pipe, fittings, and valves shall be carefully lowered into the trench in such a manner as to prevent damage to low pressure sewer system main materials and protective coatings and linings. The low pressure sewer system main materials shall not be dropped or dumped into the trench. The pipe shall be laid with the manufacturers lettering designating the type and size of pipe visible from the top of the open trench. Wherever it is necessary to deflect pipe from a straight line in either the vertical or horizontal plane to avoid obstructions or where long-radius curves are permitted, the amount of pipe or joint deflection shall not exceed fifty (50) percent of the manufacturer's recommended limit. Pipelines intended to be straight shall not deviate from the straight line at any point in excess of one (1) inch.
- c. Open cutting of roads for trenching and direct bury of low pressure sewer system mains shall not exceed 8' in width. All effort shall be made to minimize the width of the trench and the amount of restoration.
- d. All existing materials removed to facilitate the tunneling or deflecting of direct bury piping under or adjacent to existing storm piping and/or structures shall be replaced by flowable fill. Prior to placing flowable fill, the area between the direct bury piping and existing piping or structure shall be hollowed out to a defined cavity along the length of the direct bury piping. The Contractor is responsible for filling the entire cavity with flowable fill and replacing the flowable fill as necessary throughout the contract and warranty period should erosion occur.

- e. PVC pipe may be laid in the trench in single sections or preassembled multiple sections including no more than 1 full stick of pipe, 1 partial stick of pipe, and intervening required fittings and/or valves. Preassembled sections of pipe shall be carefully fed by hand or with the use of approved equipment on the pipe bed. The Contractor shall provide pockets in the pipe bed material to eliminate any concentration of loads on the bell ends or joints. The ends of mechanical joint pipe and fittings and rubber gasket joint pipe and fittings shall be clean of all dirt, grease, and foreign matter prior to installing fittings or joining of pipe sections. A joint lubricant shall be applied to all gaskets prior to joining two pipe sections together. To preclude the possibility of cross usage between wastewater and potable water piping, the joint lubricant shall have been tested and approved for potable water service. No lubricant shall be used that harbor bacteria or damage the gaskets.
- f. Cutting pipe for inserting valves, fittings, or closure pieces shall be in a neat and workmanlike manner without damaging the pipe or lining and so as to leave a smooth end at right angles to the axes of the cut pipe. The cut end of mechanical joint pipe shall be dressed to remove sharp edges or projections which may damage the rubber gasket. For push-on joints, the Contractor shall dress the pipe cut ends by beveling as recommended by the manufacturer.

3.1.2 Directional Bore of Material

- a. Proper implements, tools, and facilities shall be provided and used by the Contractor for the safe and convenient execution of the work. The Contractor shall meet the jointing and cutting pipe direct bury low pressure sewer system main piping requirements as they apply to the directional bore. A log of the bore depths shall be based on one foot intervals staking from the entry and exit locations and intermediate centerline. The vertical and horizontal location readings shall be plotted on a one inch (1") equals twenty feet (20') natural scale drawing which shall be provided to CCU within 48 hours of completion of the bore.

No electro fusion fittings shall be used with HDPE unless specific written approval is provided by CCU.

- b. For low pressure sewer system mains eight (8") inches in size or smaller, the HDPE pipe shall have the same outside diameter as the connecting mains. For larger sizes, the HDPE pipe shall have the same size or larger inside diameter as the connecting mains unless otherwise noted on the plans; provided for in the Special Provisions; or approved by CCU.
- c. The depth of all directional bores for FDOT roads shall be in accordance with the FDOT permit requirements.
- d. The slurry may be recycled for reuse in additional hole opening operations if approved by CCU or it shall be removed and disposed of at an approved dump site. No fluids shall be allowed to enter any unapproved areas or natural waterways.
- e. For directional bores under any surface water (subaqueous) the drilling Contractor must submit a 'frac-out' response plan for review and approval prior to starting the directional bore. During execution of all subaqueous directional bores, the drilling Contractor must have at the site the necessary material, equipment, and manpower to properly respond to a 'frac-out' in accordance with the 'frac-out' response plan.

3.1.3 Moling

- a. Moling shall be used to install smaller diameter low pressure sewer system service connections under road surfaces from low pressure sewer system main to the low pressure sewer system service connection in the right-of-way. The moling process consists of punching a hole beneath the surface to be spanned, installing a casing if required (schedule 40 PVC), and installing the service connection piping. The casing shall be sized to allow the service connection piping to be installed with no chafing or damage.
- b. To connect new construction low pressure sewer system piping to an existing sewer stub-out of a different diameter, the Contractor shall use CCU approved materials.

3.1.4 Marker Balls and Metallic Marker Tape

- a. Marker balls and metallic marker tape: Contractor shall provide and install metallic marker tape and provide, program, and install marker balls for all installed trenched pipe. For trenchless pipe installations the Contractor shall provide, program, and install marker balls. Metallic marker tape is not required on trenchless pipe installations. The tape shall be marked blue for potable water and purple for reclaimed water. The metallic tape shall be laid 12 to 18 inches above the pipe and the ball markers placed directly on top of the pipe or fitting. For trenchless pipe installations the marker balls shall be placed with a minimum of 18 inches of cover with the exception that no marker balls are required for that portion of pipe that lies beneath the water surface at a subaqueous crossing.
- b. Installation: The balls shall be installed at all changes of direction and fittings absent of any valve. For cul-de-sacs having continuous fused or roll piping with no in-line fittings, the balls shall be placed starting at the point of curvature of the cul-de-sac and every 50 linear foot to the end of the line. On straight runs of pipe, the balls shall be installed at every power pole. If power poles do not exist, the balls shall be placed every 150 feet from the nearest change of direction or fitting. At road and driveway crossings the marker balls shall be placed on each side of the road or driveway, two feet from the pavement or driveway edge, or as otherwise approved by CCU. On vertical deflections the marker ball shall be placed on the top fitting only.
- c. Programming: The Contractor shall program all balls and provide a copy of the programmed data in each marker ball in either Microsoft EXCEL or Access electronic format to CCU. The Contractor as-built drawings shall show the location of all marker balls.

3.1.5 Fittings

When tightening bolts, the Contractor shall bring the gland up toward the flange evenly, while maintaining approximately the same distance between the gland and the face of the flange at all points around the socket. Tighten all nuts progressively a little at a time. DO NOT over stress bolts to compensate for poor alignment. If effective sealing is not attained at the maximum torque, disassemble the joint and reassemble again after cleaning. Fittings shall be installed in accordance with the manufacturer's printed instructions.

3.1.6 Restraints

Piping shall be restrained in accordance with the CCU standard details restraint table. The table is based on a safety factor of 2.0 and takes into account variables such as type of soil, type and depth of the trench, and depth and type of pipe. In addition, the restraints may be supplemented with thrust blocks. CCU may require the engineer to provide the dimensions of the thrust block for approval prior to construction.

3.1.7 Storm Sewer Conflicts

Low pressure sewer system mains that must be installed with less than 12 inches of clearance under storm sewer pipes or structures due to existing physical limitations that prohibit deflection or directional drilling, require construction of a bridging structure that is acceptable to CCU to support the storm sewer prior to installation of the low pressure sewer system main. The low pressure sewer system main pipe section under the storm sewer pipe or structure shall be replaced with a single 20 LF stick of ductile iron pipe centered under the storm sewer pipe or structure. The ductile iron pipe shall be fully encased in an 8 mil polyethylene sleeve in accordance with AWWA C-105, Method A. Polyethylene material shall conform to ASTM Standard Specification D 1248-68. The contractor shall submit details of the proposed bridging structure and low pressure sewer system main pipe installation to CCU for review and approval prior to the start of construction at the conflict location.

3.1.8 Water Main Crossing

All low pressure sewer system mains shall cross water mains at ninety (90) degrees and with a minimum angle of forty-five (45) degrees.

3.1.9 Low Pressure Tank Installation

All low pressure tanks shall be installed according to CCU standard details specific to tank material type, load bearing and non-load bearing applications.

Only manufacturer certified contractors shall install HDPE low pressure tanks.

3.2 **TESTING MAINS, TAPPING SLEEVES, AND LOW PRESSURE TANKS**

All pressure tests shall be in accordance with AWWA C-600, latest revision. A pressure test shall be required for all installations of low pressure sewer systems mains and all appurtenances.

3.2.1 Pressure Test:

a. Pipe:

The Contractor shall hydrostatically pressure test all PVC, HDPE, and DI low pressure sewer system mains in accordance with the latest revision of AWWA C-600 series as applicable. Oil filled gauges shall only be used for all pressure tests. The tests shall be at 100 psi for a period of two (2) hours. The allowable loss for one (1) hour shall be determined by the following formula:

$$\text{Allowable Leakage} = \frac{(D)(L)(PY)}{133,200}$$

Where: D = nominal diameter of the pipe in inches
L = length of pipe in feet
PY = square root of test pressure during the leakage test in pounds per square inch

Calibrated test equipment shall be on site to verify the loss of water during the testing period.

b. Tapping Sleeves:

All low pressure sewer systems main tapping sleeves shall be hydrostatically pressure tested in accordance with the latest revision of AWWA C-600. The test shall be conducted at 100 psi for a period of two (2) hours. No loss of pressure is allowed.

c. Procedures:

Each section of pipe between valves, between the tapping sleeve and the pipe, and/or the valve and the tapping sleeve shall be slowly filled with water from a safe source, and the specified test pressure shall be applied by means of a water pump in a manner satisfactory to CCU. In the case of testing a pipe where valves do not exist, the Contractor shall plug the end of the line as approved by CCU. The pump, pipe, and/or tapping sleeve connections, gauge, and all necessary apparatus shall be furnished by the Contractor and shall be approved by CCU prior to conducting any tests. All necessary pipe taps for testing shall be made by the Contractor as approved by CCU. CCU may request testing of isolated portions between valves within the test section if a portion of that main has critical components such as multiple fittings at an extreme deflection. The Contractor shall be responsible to remove any pipe taps installed for this purpose upon completion of the test as approved by CCU.

Pressure shall be measured from sample points and/or blow-off assemblies for low pressure sewer system main pressure tests. CCU shall witness all tapping sleeve and low pressure sewer systems force main pressure tests.

3.2.2 Testing Low Pressure Tanks

Low Pressure Tanks shall be exfiltration tested. The test shall consist of plugging all inlets and outlets and filling the low pressure tank to just above the pumps. A measurement shall be taken from the rim of the tank to the water surface. The water shall remain in the tank for 24 hours. After 24 hours the distance to the water surface shall be measured again. No drop in water level is permitted for the test to be considered passed. Any tanks that fail the test shall be removed and replaced as directed by CCU.

END OF SECTION