

CHARLOTTE COUNTY UTILITIES
ENGINEERING SERVICES
INFORMATION / MEETING REQUEST FORM

Date: _____ CCU Project No.: (Filled out by CCU) _____

Developer: _____
(Company Name, Point of Contact, Phone/Fax Number)

Engineer: _____
(Company Name, Point of Contact, Phone/Fax Number)

Project Name: _____

Project Location: _____

	#of Units	Water		Sewer		Irrigation		Fire Flow	
		Req'd?	Demand	Req'd?	Demand	Req'd?	Demand	Req'd?	Demand
Single Family									
Multi-Family									
¹ Commercial									
Other									

Information Needed: _____

Meeting Desired? _____

Reason for Meeting: _____

Note: No meetings will be scheduled without this form being completed in full. If additional information is requested by CCU prior to the meeting, this information must be provided a minimum of **48** hours in advance of the scheduled meeting. If requested information is not provided within this time frame, the meeting will be cancelled without notification.

¹ See page two (2) for codes

B. Table 6-4 Schedule of daily rated gallonage for various occupancies based upon Charlotte County Code, Sect. 3-8-46.

The following usages shall be deemed to be applicable for the purpose of calculating connection fees for all new connections to the system. Commercial, Institutional and other units not identified herein shall conform to the department of health and rehabilitative services section 64E-6.008.

Types of Buildings	Usage	CODE
Bars and Cocktail Lounges	5 Gpd/seat	C01
Boarding Schools (Student and Staff)	75 Gpcd(2)	C02
Clubs (social) Country Clubs (Per member)	25 Gpcd	C03
Day Schools (Students and Staff)	10 Gpcd	C04
Drive-in Theaters (Per Car Space)	5 Gpd	C05
Factories (With Showers)	30 Gpcd	C06
Factories (Without Showers)	7 Gpd/100 Sq. Ft.	C07
Food Outlets	10 Gpd/100sf	C08
Gas Stations, per restroom	225 Gpd	C09
Hospitals (With Laundry)	250 Gpd/bed	C10
Hospitals (Without Laundry)	200 Gpd/bed	C11
Hotels and Motels (No Restaurants or Laundry) {*}	100 Gpd/rm or Unit	C12
Laundromats	225 Gpd/washer	C13
Movie Theaters, Auditoriums, Churches (Per Seat)	3 Gpd	C14
Nursing Homes	100 Gpd/bed	C15
Office Buildings	7 Gpd/100 Sq. Ft.	C16
Public Institutions (Other Than Those Listed Herein)	75 Gpcd	C17
Restaurants (Per Seat) (**)	30 Gpd/seat	C18
Restaurant Single service Articles	20 Gpd/seat	C19
Stadiums, Frontons, Ballparks, Etc. (Per Seat)	3 Gpd	C20
Stores (Without Kitchen Wastes)	5 Gpd/100Sq.Ft.	C21
Speculative Buildings	30 Gpd plus	C22
	10 Gpd/100 Sq. Ft	C23
Warehouses (each unit)	30 Gpd plus	C24
	10 Gpd/1000 Sq. Ft	C25
Single-Family Residence:		
Water: 5/8" x 3/4" meter	225 Gpd	R01
1" meter	315 Gpd	R02
1/2" meter	410 Gpd	R03
Sewer	190 Gpd	R04
Mobile Home Parks	185 Gpd/trailer	R05
Townhouse Residence (3)	155 Gpd	R06

Gpd - Gallons per Day

Gpcd - Gallons per Capita per Day

Condominiums shall be rated in accordance with the type (apartments, townhouses, etc.)

(*) Hotels and motels with other facilities to be qualified & per schedule (that is, with laundry add 50 Gpd, with restaurant add Gpd per seat).

(**) Calculations for all restaurants based upon historical data for consumption by users within Charlotte County system.

Note: Sewage gallonage refers to sanitary sewage flow on a unit basis for average daily flow in gallons per day. (Ord. No. 86-25, Sec. 5.6-17-86)